

CITY OF ELLIOT LAKE WATER TREATMENT PLANT 2021 ANNUAL REPORT

Drinking-Water System Number:	220002789
Drinking-Water System Name:	Elliot Lake Water Treatment Plant
Drinking-Water System Owner:	Corporation of the City of Elliot Lake
Drinking-Water System Category:	Water Treatment Subsystem Class 2
Period being reported:	January 01, 2021 - December 31, 2021

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [<input checked="" type="checkbox"/>] No []</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [<input checked="" type="checkbox"/>] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;"> <p>The summary report is available at City Hall, the Water Treatment Plant and is posted on the City's website at: http://cityofelliottlake.com/en/cityhall/operationsreports.asp</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
--	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
Not applicable	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [] No [] not applicable [x]

Indicate how you notified system users that your annual report is available, and is free of charge.

Public access/notice via the web

Public access/notice via Government Office

Public access/notice via a newspaper

Public access/notice via Public Request

Public access/notice via a Public Library

Public access/notice via other method _____

Describe your Drinking-Water System

The City of Elliot Lake Water Treatment Plant is classified as a Class 2 direct filtration plant.

Water is drawn from the lake through an intake structure, located in approximately 12.2 m (40 ft) of water and is gravity fed through a 295 m long marine pipeline to the low lift pumping station wet well. The water is then pumped to the main facility at 200 Spine Road.

The raw water then passes through a raw water flow meter and into reactor/mixing tanks. At this point Polyaluminum Chloride (PAC) is added to the process to aid in the production of floc (particulate matter of sufficient size to be removed by the filters).

The water then continues into the hydraulic spiral flow flocculation tanks and afterwards passes through three rectangular filters with dual media (anthracite/sand). The filtered water is collected in an underdrain system and enters a 2,300 m³ Clearwell (storage reservoir) on site.

Chlorine is added to the treated water as it leaves the filters to achieve required disinfection.

Fluoride is also added at this point. Fluoride does not play a role in the treatment process, but rather acts as an agent in the prevention of tooth decay in young children.

High Lift pumps pump the now treated water from the Clearwell through a flow meter and into the distribution system. This treated water makes its way to consumers' homes, either directly or from the standpipe storage facilities.

Lime is added to the water as it leaves the plant to aid in the prevention of corrosion in the distribution system. The lime is also used for pH and alkalinity adjustment.

List all water treatment chemicals used over this reporting period

Chlorine, Polyaluminum Chloride (PAC), Lime

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

1 Rotork Actuator - \$8,000
 Annual Diesel Load Test - \$5,000
 Fluoride Analyzer - \$5,900
 Annual Calibrations of Analyzers and Flow Meters - \$7,948
 Backflow Preventers Inspection & Maintenance - \$4,800
 Maintaining the Distribution System Infrastructure (ie: Flushing & Repairs) - \$18,000
 Pine & Poplar Watermain Replacement - \$185,000

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

INCIDENT DATE	PARAMETER	RESULTS	UNIT OF MEASURE	CORRECTIVE ACTION	CORRECTIVE ACTION DATE
Oct-21-19	Fluoride Analyzer Reading	Analyzer Reading 1.74	Mg/L	Handheld read 0.64 – Fluoride Shut Off	Ongoing
October 5 th 2020	Low Free Chlorine Residual	0.00	mg/L	Boil Water Advisory – Residual Restored and Two Sets of Samples	May 21 st 2021
January 4 th 2021	Watermain Repair	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	January 8 th 2021
January 5 th 2021	Watermain Repair	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	January 11 th 2021
February 4 th 2021	Watermain Repair	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	February 11 th 2021

February 7 th 2021	Watermain Repair	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	February 11 th 2021
February 25 th 2021	Watermain Repair	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	March 4 th 2021
March 8 th 2021	Watermain Repair	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	March 12 th 2021
March 15 th 2021	Watermain Repair	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	March 19 th 2021
April 21 st 2021	Sample Result - Microbiological	2 Total Coliform	CFU/100 mL	Resample	April 23 rd 2021
April 22 nd 2021	Watermain Repair	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	April 29 th 2021
May 10 th 2021	Connection of temporary water supply	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	May 17 th 2021
May 11 th 2021	Watermain Installation	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	May 17 th 2021
June 2 nd 2021	Hydrant Replacement	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	June 10 th 2021
June 8 th 2021	Watermain Installation	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	June 14 th 2021
June 16 th 2021	Watermain Repair	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	June 21 st 2021
June 23 rd 2021	Auto Flusher Installation	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	July 5 th 2021
August 13 th 2021	Watermain Installation	Pressure Loss	PSI	Boil Water Advisory- Flush and Two Sets of Samples	August 20 th 2021
August 16 th 2021	Watermain Installation	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	August 20 th 2021
August 20 th 2021	Service Line Repair	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	August 30 th 2021
August 31 st 2021	Watermain Repair	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	September 8 th 2021
October 13 th 2021	Watermain Repair	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	October 18 th 2021
October 19 th 2021	Watermain Repair	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	October 29 th 2021
October 23 rd 2021	Sample Result - Microbiological	9 Total Coliform	CFU/100 mL	Boil Water Advisory –Two Sets of Samples	October 29 th 2021

November 2 nd 2021	Valve Replacement	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	November 8 th 2021
November 24 th 2021	Low Free Chlorine Residual	0.00	mg/L	Boil Water Advisory – Residual Restored and Two Sets of Samples	December 2 rd 2021
November 29 th 2021	Watermain Repair	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	December 3 rd 2021
November 30 th 2021	Watermain Repair	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	December 10 th 2021
December 3 rd 2021	Sample Result - Microbiological	20 Total Coliform	CFU/100 mL	Boil Water Advisory – Two Sets of Samples	December 10 th 2021
December 14 th 2021	Watermain Repair	Pressure Loss	PSI	Boil Water Advisory – Flush and Two Sets of Samples	December 20 th 2021

Microbiological testing done under Schedule 10, 11 or 12 of the Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	52	0 – 3	0 - 19	N/A	N/A
Treated	52	N/D	N/D	52	0 - 1
Distribution	311	N/D	0 - 1	112	0 - 287

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)	Unit of Measure
Turbidity	8760	0.02 – 3.00	NTU
Chlorine	8760	0.82 – 1.88	mg/L
Fluoride	8760	0.00 – 1.43	mg/L

***NOTE:** For continuous monitors use 8760 as the number of samples.*

Note: The Fluoride has been offline since October 21st 2019.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
Municipal Drinking Water License 208-101 23 August 2011	Clarifier Overflow Suspended Solids	January 23 rd 2021	11	mg/L
		February 6 th 2021	12	mg/L
		March 7 th 2021	10	mg/L
		April 29 th 2021	10	mg/L
		May 30 th 2021	16	mg/L
		June 27 th 2021	18	mg/L
		July 30 th 2021	6	mg/L
		August 30 th 2021	4	mg/L
		September 27 th 2021	15	mg/L
		October 20 th 2021	5	mg/L
		November 30 th 2021	7	mg/L
		December 19 th 2021	8	mg/L

The Annual Clarifier Overflow Suspended Solids average for 2021 is 10.2 mg/L

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	January 18 th 2021	0.09 <MDL	µg/L	no
Arsenic	January 18 th 2021	0.2 <MDL	µg/L	no
Barium	January 18 th 2021	11.8	µg/L	no
Boron	January 18 th 2021	6	µg/L	no
Cadmium	January 18 th 2021	0.009	µg/L	no
Chromium	January 18 th 2021	0.15	µg/L	no
*Lead	not applicable for this reporting period			
Mercury	January 18 th 2021	0.01 <MDL	µg/L	no
Selenium	January 18 th 2021	0.10	µg/L	no
Sodium	8 January 2020	9.91	mg/L	no
Uranium	January 18 th 2021	0.089	µg/L	no
Fluoride	8 January 2020	0.06 <MDL	mg/L	no
Nitrite	Annual Average	0.003 <MDL	mg/L	no
Nitrate	Annual Average	0.11	mg/L	no

*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Unit of Measure	Number of Exceedances
Plumbing	not applicable for this reporting period			
Distribution	8	0.05 – 7.46	µg/L	None

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	January 18 th 2021	0.02 <MDL	µg/L	no
Atrazine	January 18 th 2021	0.01 <MDL	µg/L	no
Aldrin + Dieldrin	27 June 2018	0.01 <MDL	µg/L	no
Atrazine + N-dealkylated metabolites	January 18 th 2021	0.01 <MDL	µg/L	no
Azinphos-methyl	January 18 th 2021	0.05 <MDL	µg/L	no
Bendiocarb	27 June 2018	0.01 <MDL	µg/L	no
Benzene	January 18 th 2021	0.32 <MDL	µg/L	no
Benzo(a)pyrene	January 18 th 2021	0.004 <MDL	µg/L	no
Bromoxynil	January 18 th 2021	0.33 <MDL	µg/L	no
Carbaryl	January 18 th 2021	0.05 <MDL	µg/L	no
Carbofuran	January 18 th 2021	0.01 <MDL	µg/L	no
Carbon Tetrachloride	January 18 th 2021	0.17 <MDL	µg/L	no
Chlordane (Total)	27 June 2018	0.01 <MDL	µg/L	no
Chlorpyrifos	January 18 th 2021	0.02 <MDL	µg/L	no
Cyanazine	27 June 2018	0.03 <MDL	µg/L	no
Diazinon	January 18 th 2021	0.02 <MDL	µg/L	no
Dicamba	January 18 th 2021	0.20 <MDL	µg/L	no
1,2-Dichlorobenzene	January 18 th 2021	0.41 <MDL	µg/L	no
1,4-Dichlorobenzene	January 18 th 2021	0.36 <MDL	µg/L	no
Dichlorodiphenyltrichloroethane (DDT) + metabolites	27 June 2018	0.01 < MDL	µg/L	no
1,2-Dichloroethane	January 18 th 2021	0.35 <MDL	µg/L	no
1,1-Dichloroethylene (vinylidene chloride)	January 18 th 2021	0.33 <MDL	µg/L	no
Dichloromethane	January 18 th 2021	0.35 <MDL	µg/L	no
2-4 Dichlorophenol	January 18 th 2021	0.15 <MDL	µg/L	no
2,4-Dichlorophenoxyacetic acid (2,4-D)	January 18 th 2021	0.19 <MDL	µg/L	no
Diclofop-methyl	January 18 th 2021	0.40 <MDL	µg/L	no
Dimethoate	January 18 th 2021	0.06 <MDL	µg/L	no

Desethyl atrazine	January 18 th 2021	0.01 <MDL	µg/L	no
Diquat	January 18 th 2021	1 <MDL	µg/L	no
Diuron	January 18 th 2021	0.03 <MDL	µg/L	no
Glyphosate	January 18 th 2021	1 <MDL	µg/L	no
Heptachlor + Heptachlor Epoxide	27 June 2018	0.01 < MDL	µg/L	no
Lindane (Total)	27 June 2018	0.01 < MDL	µg/L	no
Malathion	January 18 th 2021	0.02 <MDL	µg/L	no
Methoxychlor	27 June 2018	0.01 < MDL	µg/L	no
Metolachlor	January 18 th 2021	0.01 <MDL	µg/L	no
Metribuzin	January 18 th 2021	0.02 <MDL	µg/L	no
Monochlorobenzene	January 18 th 2021	0.3 <MDL	µg/L	no
Paraquat	January 18 th 2021	1 <MDL	µg/L	no
Parathion	27 June 2018	0.02 < MDL	µg/L	no
Pentachlorophenol	January 18 th 2021	0.15 <MDL	µg/L	no
Phorate	January 18 th 2021	0.01 <MDL	µg/L	no
Picloram	January 18 th 2021	1 <MDL	µg/L	no
Polychlorinated Biphenyls (PCB)	January 18 th 2021	0.04 <MDL	µg/L	no
Prometryne	January 18 th 2021	0.03 <MDL	µg/L	no
Simazine	January 18 th 2021	0.01 <MDL	µg/L	no
THM (Annual Average)	Annual Average	44.8	µg/L	no
Total Haloacetic Acids (HAA5)	Annual Average	36.2	µg/L	no
MCPA	January 18 th 2021	0.00012 <MDL	µg/L	no
Temephos	27 June 2018	0.01 < MDL	µg/L	no
Terbufos	January 18 th 2021	0.01 <MDL	µg/L	no
Tetrachloroethylene	January 18 th 2021	0.35 <MDL	µg/L	no
2,3,4,6-Tetrachlorophenol	January 18 th 2021	0.20 <MDL	µg/L	no
Triallate	January 18 th 2021	0.01 <MDL	µg/L	no
Trichloroethylene	January 18 th 2021	0.44 <MDL	µg/L	no
2,4,6-Trichlorophenol	January 18 th 2021	0.25 <MDL	µg/L	no
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	27 June 2018	0.22 < MDL	µg/L	no
Trifluralin	January 18 th 2021	0.02 <MDL	µg/L	no
Vinyl Chloride	January 18 th 2021	0.17 <MDL	µg/L	no

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
			N/A